

screws

insert fastening screws



screws for second protective earth terminal



description		part No.	part No.
to be fitted instead of the current insert fastening screws ¹⁾		CRIC M3	
for CDA/CDC, CSAH inserts			CR VATG
for CD 15/25, CDD 38 inserts			CR VDTG
for CD 40/64, CDD 24/42/72/108, CQE, CNE, CSS,			CR VNTG
CX 8/24, CCE, CMSH, CME, CMCE, CSH, CDSH inserts			
for CP, CX 12/2, CX 6/36, CX 6/12, CX 4/0, CX 4/2 inserts			CR VPTG
¹⁾ The approved method of mounting inserts is by fixing the four screws in an ILME enclosure or housing. ILME will not be responsible for any different mounting applications. It is the responsibility of the installer to ensure the correct coupling and the continuity of the protective earth contact of the inserts.			