



HM 53

OXIDE INHIBITING COMPOUND

For Lugs, Non-Tension Splices
or Pad to Pad Applications.
Mfg. Part # 153-00201

ONE
Net Contents:
5 Gallons

DIRECTIONS:

- 1) Thoroughly clean all conductors and conductor contact surfaces with a stainless steel wire brush.
- 2) Apply a generous coating of compound to all prepared surfaces.
- 3) Remove all excess compound from parts after installation.



CAUTION



**DO NOT WIRE BRUSH PLATED
SURFACES OF CONNECTORS.**

Thomas & Betts

A Member of the ABB Group

HAZARD STATEMENT:

Toxic to aquatic life with long lasting effects.

PRECAUTIONARY STATEMENT:

Prevention: Avoid release to the environment.

Response: Collect spillage.

Storage: Store away from incompatible materials.

Disposal: Dispose of waste and residues in accordance with local authority requirements.

SUPPLEMENTAL INFORMATION:

All components are on the U.S. EPA TSCA Inventory List.

For product information call 800-816-7809

For emergencies only. Call CHEMTREC:

+1 703-741-5970



**T&B Safety Data Sheet
Number SDS-00041**

Supplier Identification:

Thomas & Betts Corporation
8155 T&B Boulevard, Memphis,
Tennessee, 38125 - www.tnb.com

WARRANTY

Limited Warranty Applies.

Refer to:

www.tnb.com/ecpwarranty
for full warranty terms.

Made in U.S.A.

TA04966 A

© 2016 Thomas & Betts. All Rights Reserved.