



TL 101

OXIDE INHIBITING COMPOUND/THREAD LUBRICANT

Mfg. Part # 753-00123

ONE
Net Contents:
1 Gallon

DIRECTIONS:

- 1) Thoroughly clean all conductors and conductor contact surfaces with a stainless steel wire brush.
- 2) Apply a generous coating of compound to all prepared surfaces.
- 3) Remove all excess compound from parts after installation.



CAUTION



**DO NOT WIRE BRUSH PLATED
SURFACES OF CONNECTORS.**

Thomas & Betts

A Member of the ABB Group

PRECAUTIONARY STATEMENT:

Prevention: Observe good industrial hygiene practices.

Response: Wash hands after handling.

Storage: Store away from incompatible materials.

Disposal: Dispose of waste and residues in accordance with local authority requirements.

SUPPLEMENTAL INFORMATION:

This product is not known to be a "Hazardous Chemical" as defined by the OSHA Hazard Communication Standard, 29 CFR 1910.1200.

All components are on the U.S. EPA TSCA Inventory List.

For product information call 800-816-7809

For emergencies only. Call CHEMTREC: +1 703-741-5970

**T&B Safety Data Sheet
Number SDS-00044**

Supplier Identification:

Thomas & Betts Corporation
8155 T&B Boulevard, Memphis,
Tennessee, 38125 - www.tnb.com

WARRANTY

Limited Warranty Applies.

Refer to:

www.tnb.com/ecpwarranty
for full warranty terms.

Made in U.S.A.

TA04976 A

© 2016 Thomas & Betts. All Rights Reserved.