



HM 52 (1/2 PINT)

OXIDE INHIBITING COMPOUND

For Full Tension Splices Only.
Mfg. Part # 195-23390

DIRECTIONS:

- 1) To open sealed spout, cut off approximately 3/8" from end.
- 2) Thoroughly clean all conductors and conductor contact surfaces with a stainless steel wire brush.
- 3) Apply a generous coating of compound to all prepared surfaces.
- 4) Remove all excess compound from parts after installation.



CAUTION



**DO NOT WIRE BRUSH PLATED
SURFACES OF CONNECTORS.**

ONE
Net Contents:
8 FL. OZ.

Thomas & Betts

A Member of the ABB Group

PRECAUTIONARY STATEMENT:

Prevention: Observe good industrial hygiene practices.

Response: Wash hands after handling.

Storage: Store away from incompatible materials.

Disposal: Dispose of waste and residues in accordance with local authority requirements.

SUPPLEMENTAL INFORMATION:

All components are on the U.S. EPA TSCA Inventory List.

For product information call 800-816-7809

For emergencies only. Call CHEMTREC: +1 703-741-5970



WARRANTY

Limited Warranty Applies. Refer to:
www.tnb.com/ecpwarranty for full warranty terms.

**T&B Safety Data Sheet
Number SDS-00040**

Supplier Identification:

Thomas & Betts Corporation
8155 T&B Boulevard, Memphis,
Tennessee, 38125 - www.tnb.com

Made in U.S.A.

TA04979 A

© 2016 Thomas & Betts. All Rights Reserved.