

Representative Image

Catalog No. TQC100F

Description: ENCLOSURE NEMA 1 FLUSH 100A

UPC No 783164020113

Home > Circuit Breakers > Circuit Breaker Enclosures

GE's circuit breaker enclosures are UL Listed, CSA Certified and are suitable for use as service equipment (except as noted). The short circuit rating of the enclosure/circuit breaker combination is equal to the short circuit rating of the installed circuit breaker.

Frame notes and/or restrictions:THQC, THHQC, TXQC (1, 2, 3 Pole)

Enclosure notes and/or limitation: Enclosure cannot accommodate a 3-pole breaker with accessory.

ACCESSORIES:

Neutral Kit (non-GF applications):included

Descriptors

Category	Circuit Breaker Enclosures
GO Schedule	B2

Specifications

Enclosure Type	NEMA Type 1
Mounting	Flush
Frame Type	Q-Line
Amperage	100 A
Material	Steel
GSA Compliance	No

Classifications

UL/CUL Listing	CSA UL

Dimensions

Height	15.25 in
Width	6.88 in
Weight	8.07 lb

by ABB